

**To: All Vendors Bidding on The College of New Jersey
Ely Gang Toilet Room Upgrades**

**From: Anup Kapur
Finance & Business Services**

Date: December 21, 2021

ADDENDUM NO. 1

ISSUE DATE: January 6, 2022

REFERENCE: The College of New Jersey
Ely Gang Toilet Room Upgrades
Project No. AB220019

Date of Original Bidding Documents: December 7, 2021

INTENT: This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents and Prior Addenda if any, as identified above. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

TCNJ Clarification:

1. Revision to scheduled work in the field. All work inside the building shall start after June 13, 2022, and be completely finished by August 8th, 2022.
2. The bidders are required to be registered with the New Jersey Department of Property Management and Construction (DPMC) and possess one of either a DPMC C008, C009, or C030 classification at the time of bid submission.

Vendor Questions:

1. The top and seamed undercounted lavatories are Corian?
TCNJ Response: Yes, or an approved equal.
2. The Supports are Corian bracketed to the wall using Angle Aluminum?
TCNJ Response: Yes

3. The End Panel is Corian Bracketed to the wall using Angle Aluminum and having a Stainless Shoe?
TCNJ Response: Yes
4. The Skirt is Corian?
TCNJ Response: Yes, or an approved equal.
5. The only Corian colors available in a $\frac{3}{4}$ " thickness, as specified, are "Cameo White" and "Glacier White" (Spec calls for Light Grey. All grey colors are $\frac{1}{2}$ " thick)?
TCNJ Response: Bidders can assume all counter materials can be up to $\frac{3}{4}$ " thickness so TCNJ has full range of color options to choose from.

Attachments:

1. Pre-bid Signup sheet

END OF ADDENDUM NO. 1