



**To: All Vendors Bidding on The College of New Jersey
Campus Steam Repairs MH - STEM**

**From: Lauren Manning
Finance & Business Services**

Date: April 28, 2026

ADDENDUM NO. 1

ISSUE DATE: April 28, 2026

**REFERENCE: The College of New Jersey
Campus Steam Repairs MH - STEM
Bid No. AB260021**

Date of Original Bidding Documents: April 16, 2026

INTENT: This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents and Prior Addenda if any, as identified above.

CLARIFICATIONS:

TCNJ is requesting that a 3-weld pass is required for all existing to new piping connections as well as new to new connections.

VENDOR QUESTIONS:

Question 1: Can you let us know what the steam operating pressure is on the system?

Response: 100 psi.

END OF ADDENDUM NO. 1